3031128

https://www.phoenixcontact.com/us/products/3031128

Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.



Feed-through terminal block, nom. voltage: 500 V, nominal current: 17.5 A, number of connections: 3, connection method: Spring-cage connection, Rated cross section: 1.5 mm², cross section: 0.08 mm² - 1.5 mm², mounting type: NS 35/7,5, NS 35/15, color: gray

Your advantages

- The consistent double function shaft offers every opportunity for time-saving potential distribution and accommodating test accessories
- · User-friendly implementation of all potential branching tasks
- · Tested for railway applications
- · Space-saving and practical multi-conductor connection without additional bridges

Commercial data

Item number	3031128
Packing unit	50 pc
Minimum order quantity	50 pc
Sales key	BE02
Product key	BE2112
Catalog page	Page 207 (C-1-2019)
GTIN	4017918186647
Weight per piece (including packing)	6.34 g
Weight per piece (excluding packing)	5.86 g
Customs tariff number	85369010
Country of origin	DE

PHŒN

3031128

https://www.phoenixcontact.com/us/products/3031128

PHŒNIX CONTACT

Technical data

Notes

General	
Note	When establishing a connection on the open housing side of a feed-through modular terminal block of the same series and size, the block must be provided with a cover if the expected insulation voltage is >320 V.
	The max. load current must not be exceeded by the total current of all connected conductors.

Product properties

Product type	Multi-conductor terminal block
Product family	ST
Area of application	Railway industry
	Machine building
	Plant engineering
	Process industry
Number of connections	3
Number of rows	1
Potentials	1
nsulation characteristics	
Overvoltage category	111
Degree of pollution	3
ctrical properties Rated surge voltage	6 kV
Rated surge voltage	6 kV
Maximum power dissipation for nominal condition	0.56 W
	0.56 W
	0.56 W 3
nnection data	
Number of connections per level Nominal cross section	3
Number of connections per level Nominal cross section	3
Number of connections per level Nominal cross section evel 1 above 1+2 below 1	3 1.5 mm²
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length	3 1.5 mm ² 8 mm 10 mm
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage	3 1.5 mm ² 8 mm 10 mm A1
Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage Connection in acc. with standard	3 1.5 mm ² 8 mm 10 mm A1 IEC 60947-7-1
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage Connection in acc. with standard Conductor cross section rigid	3 1.5 mm ² 8 mm 10 mm A1 IEC 60947-7-1 0.08 mm ² 1.5 mm ²
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage Connection in acc. with standard Conductor cross section rigid Cross section AWG	3 1.5 mm ² 8 mm 10 mm A1 IEC 60947-7-1 0.08 mm ² 1.5 mm ² 28 16 (converted acc. to IEC)
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage Connection in acc. with standard Conductor cross section rigid Cross section AWG Conductor cross section flexible	3 1.5 mm ² 8 mm 10 mm A1 IEC 60947-7-1 0.08 mm ² 1.5 mm ² 28 16 (converted acc. to IEC) 0.08 mm ² 1.5 mm ²
nnection data Number of connections per level Nominal cross section evel 1 above 1+2 below 1 Stripping length Internal cylindrical gage Connection in acc. with standard Conductor cross section rigid Cross section AWG Conductor cross section, flexible [AWG]	3 1.5 mm ² 8 mm 10 mm A1 IEC 60947-7-1 0.08 mm ² 1.5 mm ² 28 16 (converted acc. to IEC) 0.08 mm ² 1.5 mm ² 28 16 (converted acc. to IEC)

3031128

https://www.phoenixcontact.com/us/products/3031128

	PHŒNIX	
Ľ	CONTACT	

ferrule with plastic sleeve	
Nominal current	17.5 A (with 1.5 mm ² conductor cross section)
Maximum load current	17.5 A (in case of a 1.5 mm ² conductor cross section, the maximum load current must not be exceeded by the total current of all connected conductors.)
Nominal voltage	500 V
Nominal cross section	1.5 mm ²

Ex data

Rated data (ATEX/IECEx)

Identification	ⓑ II 2 GD Ex eb IIC Gb
Operating temperature range	-60 °C 110 °C
Ex-certified accessories	3030488 D-ST 2,5-TWIN
	3030789 ATP-ST-TWIN
	3036602 DS-ST 2,5
	1204504 SZF 0-0,4X2,5
	3022276 CLIPFIX 35-5
	3022218 CLIPFIX 35
List of bridges	Plug-in bridge / FBS 2-4 / 3030116
	Plug-in bridge / FBS 3-4 / 3030129
	Plug-in bridge / FBS 4-4 / 3030132
	Plug-in bridge / FBS 5-4 / 3030145
	Plug-in bridge / FBS 10-4 / 3030158
	Plug-in bridge / FBS 20-4 / 3030352
Bridge data	16.5 A / 1.5 mm²
Ex temperature increase	40 K (19.4 A / 1.5 mm²)
Rated voltage	440 V
for bridging with bridge	440 V
- At bridging between non-adjacent terminal blocks	352 V
- At cut-to-length bridging with cover	220 V
- At cut-to-length bridging with partition plate	275 V
Rated insulation voltage	400 V
output	(Permanent)
x level General	
Rated current	17.5 A
Maximum load current	17.5 A
Contact resistance	1.43 mΩ
ix connection data General	
Nominal cross section	1.5 mm ²
Rated cross section AWG	16
Connection capacity rigid	0.08 mm ² 1.5 mm ²
Connection capacity AWG	28 16
Connection capacity flexible	0.08 mm ² 1.5 mm ²



3031128

https://www.phoenixcontact.com/us/products/3031128

Connection capacity AWG	28 16
nensions	
	4.2 mm
End cover width	2.2 mm
Height	60.5 mm
Depth on NS 35/7,5	36.5 mm
Depth on NS 35/15	44 mm
torial an a ifications	
terial specifications	
Color	gray
Flammability rating according to UL 94	V0
Insulating material group	I
Insulating material	PA
Static insulating material application in cold	-60 °C
Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))	125 °C
Relative insulation material temperature index (Elec., UL 746 B)	130 °C
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R26	HL 1 - HL 3
Calorimetric heat release NFPA 130 (ASTM E 1354)	27,5 MJ/kg
Surface flammability NFPA 130 (ASTM E 162)	passed
Specific optical density of smoke NFPA 130 (ASTM E 662)	passed
Smoke gas toxicity NFPA 130 (SMP 800C)	passed
	width End cover width Height Depth on NS 35/7,5 Depth on NS 35/15 terial specifications Color Flammability rating according to UL 94 Insulating material group Insulating material group Insulating material application in cold Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Relative insulation material temperature index (Elec., UL 746 B) Fire protection for rail vehicles (DIN EN 45545-2) R22 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R24 Fire protection for rail vehicles (DIN EN 45545-2) R26 Calorimetric heat release NFPA 130 (ASTM E 1354) Surface flammability NFPA 130 (ASTM E 162)

Electrical tests

Surge voltage test

Test voltage setpoint	7.3 kV
Result	Test passed
Temperature-rise test	
Requirement temperature-rise test	Increase in temperature ≤ 45 K
Result	Test passed
	Test passed
Short-time withstand current 1.5 mm ²	0.18 kA
Result	Test passed
Power-frequency withstand voltage	
Test voltage setpoint	1.89 kV
Result	Test passed

Mechanical properties

Mechanical data



3031128

https://www.phoenixcontact.com/us/products/3031128

Open side panel	Yes
chanical tests	
Aechanical strength	
Result	Test passed
Attachment on the carrier	
DIN rail/fixing support	NS 32/NS 35
Test force setpoint	1 N
Result	Test passed
Fest for conductor damage and slackening	
Rotation speed	10 (+/- 2) rpm
Revolutions	135
Conductor cross section/weight	0.14 mm² / 0.2 kg
	0.2 mm² / 0.2 kg
	1.5 mm² / 0.4 kg
Result	Test passed
	400
Aging	
Temperature cycles	192 Test passed
	192 Test passed
Temperature cycles Result Needle-flame test	
Temperature cycles Result	
Temperature cycles Result Needle-flame test	Test passed
Temperature cycles Result Needle-flame test Time of exposure Result	Test passed 30 s
Temperature cycles Result Needle-flame test Time of exposure Result	Test passed 30 s
Temperature cycles Result Needle-flame test Time of exposure Result Dscillation/broadband noise	Test passed 30 s Test passed
Temperature cycles Result Needle-flame test Time of exposure Result Oscillation/broadband noise Specification	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05
Temperature cycles Result Needle-flame test Time of exposure Result Descillation/broadband noise Specification Spectrum	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted
Temperature cycles Result Needle-flame test Time of exposure Result Dscillation/broadband noise Specification Spectrum Frequency	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz
Temperature cycles Result Needle-flame test Time of exposure Result Specification/broadband noise Spectrum Frequency ASD level	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz
Temperature cycles Result Needle-flame test Time of exposure Result Specification/broadband noise Spectrum Spectrum Frequency ASD level Acceleration	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz 3.12g
Temperature cycles Result Needle-flame test Time of exposure Result Specification/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz $3.12g$ 5 h
Temperature cycles Result Needle-flame test Time of exposure Result Specification/broadband noise Specification Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz 3.12g 5 h X-, Y- and Z-axis
Temperature cycles Result Needle-flame test Time of exposure Result Specification/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz $3.12g$ 5 h X-, Y- and Z-axis Test passed
Temperature cycles Result Result Time of exposure Result Specification/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Test directions Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s ²) ² /Hz 3.12g 5 h X-, Y- and Z-axis
Temperature cycles Result Result Time of exposure Result Specification/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s²)²/Hz 3.12g 5 h X-, Y- and Z-axis Test passed DIN EN 50155 (VDE 0115-200):2008-03 Half-sine
Temperature cycles Result Result Time of exposure Result Specification/broadband noise Specification Spectrum ASD level Acceleration Test duration per axis Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted f ₁ = 5 Hz to f ₂ = 250 Hz 6.12 (m/s²)²/Hz 3.12g 5 h X-, Y- and Z-axis Test passed DIN EN 50155 (VDE 0115-200):2008-03 Half-sine 5g
Temperature cycles Result Result Time of exposure Result Specification/broadband noise Specification Spectrum Frequency ASD level Acceleration Test duration per axis Result	Test passed 30 s Test passed DIN EN 50155 (VDE 0115-200):2018-05 Service life test category 2, bogie-mounted $f_1 = 5$ Hz to $f_2 = 250$ Hz 6.12 (m/s²)²/Hz 3.12g 5 h X-, Y- and Z-axis Test passed DIN EN 50155 (VDE 0115-200):2008-03 Half-sine



3031128

https://www.phoenixcontact.com/us/products/3031128

Result	Test passed
mbient conditions	
Ambient temperature (operation)	-60 °C 110 °C (Operating temperature range incl. self-heating for max. short-term operating temperature, see RTI Elec.)
Ambient temperature (storage/transport)	-25 °C 60 °C (for a short time, no longer than 24 h, -60°C to +70°C)
Ambient temperature (assembly)	-5 °C 70 °C
Ambient temperature (actuation)	-5 °C 70 °C
Permissible humidity (operation)	20 % 90 %
Permissible humidity (storage/transport)	30 % 70 %
ndards and regulations Connection in acc. with standard	IEC 60947-7-1
unting	
Mounting type	NS 35/7,5

Phoenix Contact 2024 © - all rights reserved https://www.phoenixcontact.com

Phoenix Contact USA 586 Fulling Mill Road Middletown, PA 17057, United States (+717) 944-1300 info@phoenixcon.com